

Drinking Water Testing Results
Green County (November/December 2014)
Towns: Decatur, Jefferson, Spring Grove, Sylvester

29 Water Samples

Number of Tests	Percentage of Total*	Result
6	(21%)	Positive for Bacteria
10	(34%)	Nitrates 10 ppm or greater.
1	(6%)	Iron 0.3 mg/l or greater.
1	(6%)	Zinc 5 mg/l or greater.
0	(0%)	Triazine 3.0 ug/l or greater.
1	(6%)	Copper 1.3 mg/l or greater.
0	(0%)	Lead 0.015 mg/l or greater.
0	(0%)	Arsenic 0.05 mg/l or greater.

**Percentages are out of the number of samples tested for that item, not necessarily out of the total number of samples.*